

The following tests were witnessed by a representative of the FDIA

FDIA Fire Alarm Cable Testing

Testing Conducted On Standard PH 30 Cables on 15/07/2016

Sample 1	Brand Name On Cable	FIRE-TRON
	Distributed By	Velocity Cable Company
	Sample Supplied By	Velocity Cable Company
	Cable Description as printed on Cable	FIRE-TRON 2 X 1.00mm 100/100V PH30 CEI 20-105 UMI 9795 36762 C-4 (U0=400v) EN50200 CEI EN 61032-3-25 T100000198 CE
	Fire Test Result	Cable passed the 30Min fire & shock test. Shock at 5 minute intervals in accordance with EN50200.
	Cable General	Red & Black Silicone Insulated Cores. Cable sheath is Halogen Free

Date: Friday 15th June

Time: 11.45

Samples Tested: 1



